

## Anlage 3

### Zweckverband Kläranlage Böblingen-Sindelfingen Schlammabfuhr

	Klärschlamm nach Entwässerung	Klärschlamm zur landwirtschaftlichen Verwertung	Klärschlamm zur Verbrennung	Kalk-Verbrauch	FeCl <sub>3</sub> -Verbrauch	Asche	Polymere	TR nach Entwässerung
1992	16.300 t	16.300 t	0 t	952 t	412 t	1.217 t	0 t	
1993	15.444 t	15.444 t	0 t	1.382 t	433 t	146 t	0 t	
1994	14.668 t	14.668 t	0 t	1.173 t	501 t	7 t	0 t	
1995	15.282 t	15.282 t	0 t	1.112 t	485 t	0 t	0 t	
1996	15.595 t	15.595 t	0 t	1.116 t	571 t	0 t	0 t	
1997	16.009 t	16.009 t	0 t	1.113 t	513 t	0 t	0 t	
1998	7.729 t	7.729 t	0 t	135 t	69 t	0 t	9,5 t	
1999	8.050 t	8.050 t	0 t	0 t	0 t	0 t	12,2 t	
2000	7.360 t	7.360 t	0 t	0 t	0 t	0 t	10,1 t	
2001	7.579 t	7.579 t	0 t	0 t	0 t	0 t	10,8 t	
2002	8.735 t	5.920 t	2.815 t	0 t	0 t	0 t	13,8 t	
2003	8.293 t	0 t	8.293 t	0 t	0 t	0 t	13,2 t	37%
2004	7.689 t	0 t	7.689 t	0 t	0 t	0 t	13,1 t	37%
2005	7.946 t	0 t	7.946 t	0 t	0 t	0 t	14,3 t	37%
2006	7.925 t	0 t	7.925 t	0 t	0 t	0 t	15,0 t	37%
2007	7.528 t	0 t	7.528 t	0 t	0 t	0 t	15,0 t	35%
2008	8.060 t	0 t	8.060 t	0 t	0 t	0 t	14,0 t	34%
2009	7.293 t	0 t	7.293 t	0 t	0 t	0 t	19,0 t	35%
2010	7.716 t	0 t	7.716 t	0 t	0 t	0 t	18,0 t	33%
2011	7.701 t	0 t	7.701 t	0 t	0 t	0 t	17,0 t	34%
2012	8.100 t	0 t	8.100 t	0 t	0 t	0 t	18,0 t	34%
2013	8.384 t	0 t	8.384 t	0 t	0 t	0 t	18,0 t	35%
2014	8.277 t	0 t	8.277 t	0 t	0 t	0 t	18,0 t	32%
2015	8.364 t	0 t	8.364 t	0 t	0 t	0 t	18,0 t	32%
2016	8.606 t	0 t	8.606 t	0 t	0 t	0 t		33%
2017	7.863 t	0 t	7.863 t	0 t	0 t	0 t	18,0 t	33%
2018	9.030 t	0 t	9.030 t	0 t	0 t	0 t	18,0 t	33%
2019	7.996 t	0 t	7.996 t	0 t	0 t	0 t	15,7 t	33%
2020	8.004 t	0 t	8.004 t	0 t	0 t	0 t	18,4 t	33%

